



Test Report issued under the responsibility of:



TEST REPORT  
IEC 60947-2  
**Low-voltage switchgear and controlgear - Part 2: Circuit-breakers**



Report Reference No. ....: 00901-CB2017CQC-075336  
Date of issue .....: 2019-02-25  
Total number of pages .....: 153

**CB Testing Laboratory** .....: Shanghai Testing & Inspection Institute for Electrical Equipment (STIEE)  
Address .....: 505 Wu Ning Rd. Shanghai 200063, P.R. CHINA



Applicant's name .....: ZhejiangTENGEN Electrics Co., Ltd.  
Address .....: Sulv Industry Zone, Liushi, Yueqing, Zhejiang, P.R. China

**Test specification:**  
Standard .....: IEC 60947-2:2006 (Fourth Edition) + A1: 2009 + A2: 2013  
Test procedure .....: CB scheme  
Non-standard test method .....: N/A

**Test Report Form No.** .....: IEC60947\_2G  
Test Report Form(s) Originator .....: DEKRA Certification BV  
Master TRF .....: Dated 2013-11

**Copyright © 2013 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.**  
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.  
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.  
**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

Test item description .....: Moulded Case Circuit Breaker DC  
Trade Mark .....: TENGEN  
Manufacturer .....: ZhejiangTENGEN Electrics Co., Ltd.  
Sulv Industry Zone, Liushi, Yueqing, Zhejiang, P.R. China  
Model/Type reference .....: TGM3DC-125M  
Ratings .....: Ue: DC250V/500V(2P in series), 750V/1000V(4P in series)  
In: 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A

Testing procedure and testing location:		
<input checked="" type="checkbox"/>	<b>CB Testing Laboratory:</b>	Shanghai Testing & Inspection Institute for Electrical Equipment (STIEE)
<b>Testing location/ address.....:</b>		505 Wu Ning Rd. Shanghai 200063, P.R. CHINA
<b>Tested by (name + signature).....</b>		Cui Tao/ Engineer 
<b>Approved by (name + signature) .....</b>		WeiQingYuan/SeniorEngineer 
<input type="checkbox"/>	<b>Testing procedure: TMP</b>	N/A
<b>Testing location/ address.....:</b>		N/A
<b>Tested by (name + signature).....</b>		N/A
<b>Approved by (name + signature) .....</b>		N/A
<input type="checkbox"/>	<b>Testing procedure: WMT</b>	N/A
<b>Testing location/ address.....:</b>		N/A
<b>Tested by (name + signature).....</b>		N/A
<b>Witnessed by (name + signature) .....</b>		N/A
<b>Approved by (name + signature) .....</b>		N/A
<input type="checkbox"/>	<b>Testing procedure: SMT</b>	N/A
<b>Testing location/ address.....:</b>		N/A
<b>Tested by (name + signature).....</b>		N/A
<b>Approved by (name + signature) .....</b>		N/A
<b>Supervised by (name + signature)...</b>		N/A

**Summary of testing:**

In case of alternative test programs for circuit breakers with a different number of poles, the following program is used:

- Programme 1 (three pole fully tested)  
 Programme 2 (four pole fully tested)  
 Alternative program not applicable

**Tests performed(name of test and test clause 1/2):**

Type	Ue	In	Pole	Sequence
TGM3DC-125M(#01)	DC500V	125A	2P in series	I
TGM3DC-125M(#02)	DC1000V	125A	4P in series type1	I
TGM3DC-125MZ(#03)	DC1000V	125A	4P in series type1	I <sup>1)</sup>
TGM3DC-125MP(#04)	DC1000V	125A	4P in series type1	I <sup>2)</sup>
TGM3DC-125M(#05)	DC1000V	125A	4P in series type3	I
TGM3DC-125M(#06)	DC500V	125A	2P in series	II,III
TGM3DC-125M(#07)	DC1000V	125A	4P in series type1	II,III
TGM3DC-125M(#08)	DC1000V	16A	4P in series type1	II,III
TGM3DC-125M(#09)	DC500V	16A	2P in series	II,III
TGM3DC-125M(#10)	DC250V	125A	2P in series	II,III
TGM3DC-125M(#11)	DC250V	16A	2P in series	II,III
TGM3DC-125M(#12)	DC1000V	125A	4P in series type2	II,III
TGM3DC-125M(#13)	DC1000V	125A	4P in series type3	II,III
Undervoltage release AC220/230V assembled on TGM3DC-125M(#14)	-	-	-	N
Undervoltage releaseAC380/400V assembled on TGM3DC-125M(#15)	-	-	-	N
Motor operator AC100- 240V/DC100-220V assembled on TGM3DC-125M(#16)	-	-	-	N
Motor operator AC380/400Vassembled on TGM3DC-125M(#17)	-	-	-	N

**Tests performed (name of test and test clause 2/2):**

Auxiliary Testing(IEC 60947-5-1)

Auxiliary contact(#18)	AC400V	0,3A	AC-15	II
Auxiliary contact(#19)	DC250V	0,15A	DC-13	II
Auxiliary contact(#20)	AC400V	0,3A	AC-15	III
Auxiliary contact(#21)	AC400V	1A	AC-15	IV

Remark:

- 1) Only test items for clause 8.3.3.3.3, 8.3.3.3.4, 8.3.3.9
- 2) Only test items for clause 8.3.3.3.2, 8.3.3.3.3, 8.3.3.3.4, 8.3.3.9

**Testing location:**

Shanghai Testing & Inspection Institute for Electrical Equipment (STIEE)  
505 Wu Ning Rd. Shanghai 200063, P.R. CHINA

**Summary of compliance with National Differences:** N/A